


- APPROVED ASSEMBLIES ARE REQUIRED TO HAVE RESILIENT SEATED SHUT-OFF VALVES AND TEST COCKS AS INTEGRAL PARTS OF THE ASSEMBLIES OTHERWISE THE APPROVAL IS VOIDED.
- ω 2) ASSEMBLY MUST BE ACCESSIBLE FOR TESTING PROTECTION FROM FREEZE DAMAGE MAY BE REQUIRED IN EXPOSED AREAS. AND MAINTENANCE.

9

- 4 NO CONNECTIONS OR TEES WILL BE ALLOWED BETWEEN SERVICE CONNECTION AND ASSEMBLY.
- 5) INSTALLATION AND OPERATION MUST COMPLY WITH STANDARDS SET FORTH BY A.W.W.A. AND ALL FEDERAL, STATE, AND LOCAL LAWS, RULES, REGULATIONS, ORDERS, CODES, AND ORDINANCES.
- THE DCDA SHALL BE INSTALLED AS CLOSE TO THE PROPERTY LINE AS PRACTICAL. ANY DEVIATION FROM THIS METHOD MUST BE APPROVED BY CLWSC PRIOR TO INSTALLATION.
- ASSEMBLY MAY BE INSTALLED BELOW GRADE WITH APPROVAL BY CLWSC.



AVAILABLE UPON REQUEST.

GENERAL NOTES:

WATER SERVICE COMPANY Canyon Lake, Texas 78133 1399 Sattler Road (830) 964-3854 CANYON LAKE

